

Hereford BSP



DNOA Decision

Remove

Constraint description

Hereford (Walham area) is a site consisting of two 132/66 kV Grid Transformers (GT4 and GT5) fed via two 132 kV circuits from Port Ham Grid Supply Point (GSP). Load growth indicates that the site will exceed its firm capacity under N-1

Reinforcement description

Installing a third 132/66 kV grid transformer (GT6) at Hereford.



Constraint Season
Winter



Flexibility Product
Secure



Outage Type
N-1

Justification for decision

Reinforcement works have been completed, resolving this constraint.

Constraint management timeline

2024 H1 None
2023 H2 Maintain Active
2023 H1 Maintain Active
2022 H2 Procurement
2022 H1 Procurement
2021 H2 Procurement
2021 H1 Procurement
2020 H2 Signposting
2020 H1 Signposting
2019 H2 Signposting
2019 H1 Signposting

EPRC: N/A

Constraint Type: Thermal

Estimated flexibility price (£) and volumes (MWh) per year under Best View:

	2024	2025	2026	2027	2028	2029
Availability	-	-	-	-	-	-
Utilisation	-	-	-	-	-	-



For more information visit: nationalgrid.co.uk/network-flexibility-map-application