


NEXT GENERATION NETWORKS

Distribution Networks: A Balancing Act

Thursday 20th November 2014

Roger Hey

Future Networks Manager



Agenda

Session 1 Alternative Connection Agreements

10:20-12:00

Alternative Connections Agreements – DG viewpoints

Coffee Break

Network planning, constraints and Alternative Connections

Lunch & Networking

12:00-13:00

Session 2 – Demand Side Response (DSR)

13:00-13:45

Demand Side Response

Session 3 – Energy Storage

13:45-15:15

Learning from Energy Storage Projects

Customer Slot – How they are going to trial Energy Storage

Identifying energy storage opportunities - distribution network

Wrap up and panel session questions


End of Dissemination Event conversations


15:15-16:00

WESTERN POWER DISTRIBUTION


KEY FACTS:

- Wholly owned by Pennsylvania Power & Light (PPL - NYSE listed)
- 4 UK Distribution Licences
- 7.7 million customers
- 55,000 sq km area
- Largest length UK network
216,000 kms of overhead lines and underground cables, and 184,000 substations





- Limited capacity
- Passive design / operation
- Centralised Generation
- Limited Visibility
- One-way power flow
- Load centric design



- Reduced headroom
- Increased Intelligence / Active Management
- Distributed Generation
- Need for increased visibility
- Two-way power flows
- Utilisation centric design

Innovation Strategy

Networks



Demonstrating alternative investment strategies to facilitate the UK's Low Carbon Transition

Customers



Testing innovative solutions to make it simple for customers to connect Low Carbon Technologies

Performance



Developing new solutions to improve network and business performance

Stakeholder Engagement and Knowledge Management

Super Conducting
Fault Current Limiter



Isentropic Energy
Storage



Carbon Tracing

WESTERN POWER
DISTRIBUTION
CONTROL
CENTRE LINKS

WESTERN POWER
DISTRIBUTION
EARLY LEARNING

WESTERN POWER
DISTRIBUTION
SEASONAL
GENERATION

WESTERN POWER
DISTRIBUTION
SUBURBAN
PV IMPACT

WESTERN POWER
DISTRIBUTION
LOW CARBON HUB

WESTERN POWER
DISTRIBUTION
NETWORK
TEMPLATES

WESTERN POWER
DISTRIBUTION
SOLA BRISTOL

WESTERN POWER
DISTRIBUTION
FALCON

WESTERN POWER
DISTRIBUTION
FLEXDGRID

WESTERN POWER
DISTRIBUTION
SOLAR STORAGE

WESTERN POWER
DISTRIBUTION
ISLES OF SCILLY
SMART GRID

WESTERN POWER
DISTRIBUTION
ECHO

WESTERN POWER
DISTRIBUTION
SMART HOOKY

WESTERN POWER
DISTRIBUTION
HV VOLTAGE
CONTROL

WESTERN POWER
DISTRIBUTION
COMMUNITY
ENERGY ACTION


WESTERN POWER
DISTRIBUTION
LV SENSORS

WESTERN POWER
DISTRIBUTION
ELECTRIC
BOULEVARDS


Benefits from previous R&D projects

The following projects have been fully implemented across WPD since 2005:

- **Reference Model Network** – Improved Network planning and study techniques
- **Helicopter Inspection Techniques** – Better condition assessment and post-fault restoration
- **Understanding High Penetrations of Distributed Generation** – Modification to conventional network design assumptions
- **Climate Change and Weather Analysis** – New methodologies and probability based predictions to assess network impacts of climate change
- **Non-intrusive testing of tower foundations** – New testing techniques implemented to improve accuracy and speed of response
- **Control system automation algorithm** – Development of reliable and secure protocols for self-healing networks leading to improved network performance
- **11kV Voltage Optimisation project** - Demonstrated of wide scale voltage reduction without adverse impact on customers
- **Electric Vehicles** – Investigation into the impact of charging electric vehicles on Low Voltage networks. Learning incorporated into IET wiring regulations and DNO standards.
- **Harmonic issues on distribution networks** – Investigation into potential harmonic problems caused by converter plant. Learning influenced ENA planning guidelines.
- **Condition Based Risk Management (CBRM)** - Delivered a tool that determines optimum replacement triggers for network assets.
- **Alternative Connections** – Offering Timed, Soft Intertrip and Active Network Management (ANM) generation connections



Innovation for future networks




Our LCNF and IFI projects indicate that there are some smarter solutions which could be used to complement conventional network reinforcement.

We have already started to actively balance generation export with demand profiles, unlocking additional network capacity.

Most innovative solutions require further development and/or cost reduction before they can be applied in the normal course of business.

Being discussed at today's dissemination event:

- Alternative Connections
- Demand Side Response
- Energy Storage



Session 1

Alternative Connections



Alternative Connections Agreements – DG viewpoints

20.11.2014

Outline

- Introduction
- Low Carbon UK – Solar PV
- Challenges
 - Grid connection
 - Conventional connection
 - Alternate connection

juwi at a Glance



Established: 1996 (two-man office)

Employees: more than 1,100 (worldwide)

Project development of regenerative power plants

- planning
- construction
- financing
- technical consulting

Our vision: 100% renewable energy

Our claim: Energy is here

➔ Let's work together to implement renewable energies economically and reliably with passion.



Headquarters in Wörrstadt,
Rhineland-Palatinate



50 MW wind farm Guanacaste in
Costa Rica



53 MW solar park Lieberose

Juwi's Sources of Energy



Wind Energy

- more than 252 wind turbines (at 85 locations)
- more than 1000 MW of installed capacity
- total investment: approx. € 1,35 billion
- annual energy production: approx. 2,3 billion kWh



Plouguin wind farm, Bretagne

Solar Energy


- more than 1,500 PV installations
- more than 1200 MW of installed capacity
- total investment: approx. € 2,7 billion
- annual energy production: approx. 950 mio kWh



PV-free-field installation Drama, Greece

Solar-Hydrogen


- 1 green hydrogen production plant
- TSB funded project: approx. £ 130k



Solar-H2: Green hydrogen production, UK

Offices, Projects and Markets

Projects and Markets



Offices

- **Europe**

Germany, France, UK, Italy, Greece

- **Americas**

USA, Chile

- **Asia**

India, Singapore, Japan, Thailand

- **Africa**

South Africa



Hollies solar farm, Skegness, Total capacity: 8605 kWp



Ninnis solar farm, Cornwall, Total capacity: 3880 kWp




King's Lynn Solar farm, King's Lynn, Total capacity: 1332 kWp

Outline

- Introduction
- **Low Carbon UK – Solar PV**
- Challenges
 - Grid connection
 - Conventional connection
 - Alternate connection

Low Carbon UK – Solar PV

Global irradiation and solar electricity potential
Horizontally mounted photovoltaic modules




Incentive Schemes

- **Feed in Tariff (FIT):**
 - Started in April 2010 @ 29p/kWh (250kWp - 5MWp)
 - ~70% reduction within 1 years

- **Renewable obligation Certificate (RoC)**
 - Started with no capacity constraint
 - No RoC for > 5MWp after March 2015

- **CFD bidding process**
 - Started in Oct-Nov 2014
 - Uncertainty ??

Installed capacity – the biggest solar market in Europe



© NPD Solarbuzz, August 2014.


Source: NPD Solarbuzz UK Deal Tracker report, July 2014 & NPD Solarbuzz European PV Markets Quarterly, July 2014.

QTD: Quarter-to-Date

Outline

- Introduction
- Low Carbon UK – Solar PV
- Challenges
 - Grid connection
 - Conventional connection
 - Alternate connection

Solar PV development challenges

- **FIT in April 2010** vs **FIT in September 2011**


miscalculation

Tariff was too high

miscalculation

Tariff was too low

Only considered module price reduction and Missed the grid connection change
- **EU anti dumping tariff on module**
- **Digression of RoC vs increasing grid connection charge**
- **Rate of deployment of PV is faster than up gradation of grid network**

Conventional grid connection

| Type of offer | What is this? |
|-----------------------------------|---|
| Budget Estimate | A basic desk top estimate without any system studies. It is an indicative offer. |
| Feasibility Study | A chargeable electricity system study to give a more detailed view of likely connection costs for various options. |
| S16 Connection Offer | DNO will quote for undertaking all the contestable and non - contestable works. |
| SLC15 CIC Connection Offer | If you want to arrange to do the contestable works yourself (ICP), DNO will quote for the non-contestable works only. |

Full Grid Application Process

1. Site details
2. Number of generation sets
3. Power station export and import requirements
4. Power station maximum fault current
5. Generation set active & reactive power capacity
6. etc

Generator Application Form

1. Site location and Module layout
2. Proposed Metering / substation Location
3. AC Single Line Diagram (SLD)
4. Datasheet / Technical specification of Transformer
5. Datasheet / Technical specification of Inverter
6. Short circuit current details of inverter
7. Harmonics of inverter
8. Letter of authority from land owner

Supporting Documents

**Grid Application to DNO:
SLC 15 and Section 16**

30 Days

PoC

65 Days

Grid offer

Grid Connection - is there any challenges?


- Available **Capacity**:
 - speed of PV deployment exceeds speed of grid upgrades –
 - developers are competing for best connections
- Process difficulties:
 - budget offer – **is it reliable?**
 - increasing **interactivity**
 - different approaches from different DNOs
- **Connection charge???**
- **Increasing connection charge even after accepting the binding offer**
- Outage booking: 'winter Clock Change period' vs Regulation
- Approved switchgear lead time vs project completion date
- Grid maintenance and system generation loss (kWh)

Outline



- Introduction
- Low Carbon UK – Solar PV
- Challenges
 - Grid connection
 - Conventional connection
 - Alternate connection

juwi



Highlights of the offer



Notice of Interactivity

Please note that this Connection Offer is deemed to be an **Interactive Connection Offer** and WPD is notifying you of the fact in accordance with paragraph 2.24 of our Statement of Methodology and Charges for Connection.

This means that WPD has received a separate application for a connection that makes use of the same part of WPD's **Existing Network**, or **Committed Network**, or otherwise has a material effect on the operation of WPD's Distribution System.

Your Connection Offer is fourth in the **Interactive Queue**.

4 Connection Charge

- 4.1 The contribution required for providing an electricity connection to the Customer's Premises is:

£ 11,654,352.14 including VAT which shall be payable at the appropriate rate (the "Connection Charge").

Outline

- Introduction
- Low Carbon UK – Solar PV
- Challenges
 - Grid connection
 - Conventional connection
 - Alternate connection

Case Study – Alternate connection offer



2 Basis of the Alternative Connection Offer

2.1 Customer's Installation

2.1.1 WPD understands that the proposed Customer's Installation will comprise the following:-

- 10 x 0.88MVA (0.88MW), 360V solar inverters; and
- 5 x 2MVA, 33/0.36/0.36kV transformers

2.2 Connection and Supply Specification

2.2.1 The characteristics of the new connections will be:

Nominal Voltage at Connection Point: 33,000 V

No of Phases: 3

Nominal Frequency: 50 Hz

Maximum Export Capacity: 8,800 kVA @ Unity Power Factor

Maximum Import Capacity: 80 kVA @ 0.95 Power Factor

Acceptable Power Factor Bandwidth for Export Capacity: Unity with transient excursions to 0.95 lagging and leading power factor being accepted (subject to agreement of National Grid Electricity Transmission plc (NGET)).

Acceptable Power Factor Bandwidth for Import Capacity: 0.95 lag to 0.95 lead

Highlights of the offer



Last In, First Out Position (LIFO)

Where more than one connection within a given section of network needs to be curtailed then the connections shall be curtailed in order, with the last comer being curtailed first and the first comer being curtailed last. When the network limitation is lifted then the connections are restored to normal in the opposite order, i.e. the first comer is restored first and the last comer is restored last. This principle is known as Last In First Out (LIFO). Where a group of connections are handled in this way they are known as a LIFO stack.

The LIFO position number indicates the number of generators connected through alternative connections ahead of you in the LIFO queue.

Your generator will hold the following LIFO position: [5]

The following generation is above you in the LIFO queue:

| Generation Type | Generation Capacity (MW) | Number of Connections |
|-------------------|--------------------------|-----------------------|
| Wind | 10 | 1 |
| Solar | 24.32 | 3 |
| Synchronous/Other | 0 | 0 |

Highlights of the offer - original



Curtailment under normal running conditions

A study has been completed to assess the level of curtailment of this connection under normal running conditions. This study is based on recent historic trends and predicted generation output. Further details on the assumptions can be made available on request.

| | |
|---|---|
| Estimated worst case with all generation at maximum output and a reduction in current demand by 25% | Estimated 87.7% Energy constrained from 115,493.6 MWh output over 18 months |
| Estimated current scenario with no smart grid technology | Estimated 15.8% Energy constrained from 19,789.2 MWh output over 18 months |
| Estimated current scenario with smart grid technology | Estimated 16.7% Energy constrained from 19,789.2 MWh output over 18 months |

Connection Charge

The contribution required for providing an electricity connection to the Customer's Premises is:

£ 453,494.17 excluding VAT which shall be payable at the appropriate rate (the "Connection Charge").

Highlights of the offer - current

| Generation Type | Generation Capacity (MW) | Number of Connections |
|-------------------|--------------------------|-----------------------|
| Wind | 10 | 1 |
| Solar | 24.32 | 3 |
| Synchronous/Other | 0 | 0 |



Table 1

| Generation Type | Generation Capacity (MW) | Number of Connections |
|-------------------|--------------------------|-----------------------|
| Wind | 10 | 1 |
| Solar | 12 | 2 |
| Synchronous/Other | 0 | 0 |

Table 2

| | |
|--|---|
| Estimated worst case with all generation at maximum output and a reduction in current demand by 25% | Estimated 50.8% Energy constrained from 115,494 MWh output over 18 months |
| Estimated current scenario with no smart grid technology | Estimated 0.2% Energy constrained from 19,789 MWh output over 18 months |
| Estimated current scenario with smart grid technology | Estimated 0.2% Energy constrained from 19,789.2 MWh output over 18 months |

£ 453,494.17 excluding VAT which shall be payable at the appropriate rate (the "Connection Charge").

Alternate connection – at a glance




- New connection scheme and nervousness within the stakeholders
- Awareness required – potential option for DG depending on the LIFO position
- Constrain analysis considered the extreme worse case scenario – more realistic scenario can allow more limited curtail connection
- Energy curtailed model need to considerer the DC/AC ratio
- Security on the level of curtailment – allows investor's confidence

Innovative connection

- Wind – Solar or Solar – Wind integration

Spare grid capacity > Shared grid connection > Power controller



Key Factors – how to overcome challenges

- **Extend the alternate connection network** (when, where, how to be notified)
- **Other innovative connections**
- **Different AM & PM tariffs can help maximum utilisation of the available grid and help demand management to match with the base load**
- **Active and reactive power managements of the inverters in the constrained networks**
- **Collaborative approach with DNOs & DGs**

Thank You for Your Attention

Dr. Jyoti Roy
Head of Engineering and Technology Expert
juwi Renewable Energies Limited
Nelson House, Central Boulevard Blythe
Valley Park, Shirley, Solihull West Midlands,
B90 8BG, UK
Tel. +44 (0) 121 733 1119 Ext 105
Mob. +44 (0) 782 377 7559
Email: roy@juwi.co.uk
www.juwi.co.uk



Coffee Break


NEXT GENERATION NETWORKS

Distribution Networks: A Balancing Act

Network planning, constraints and
Alternative Connections

Ben Godfrey

Innovation & Low Carbon Networks
Engineer



Agenda

- 1) Introducing Network Planning and Constraints
 - Limitations influencing Generation
 - Security of Supply
 - 2) Alternative Connections
 - Timed
 - Soft-Intertrip
 - Active Network Management
 - 3) Roll Out
 - 4) Consortia - shared conventional reinforcement
-

Western Power Distribution DG Levels



Western Power Distribution DG Levels

- 7.8 Million Customers
 - 55,000 sq km area
 - 216,000 kms of linear assets
 - 184,000 substations

 - DG Capacity Connected up to Q3 2014 – **4,100** MVA
 - DG Connected March to September 2014 – **640** MVA
 - DG Capacity Offered and Accepted – **8,800** MVA
-

What Influences Generation Connections?

Main technical barriers:

- I. Power flow, thermal rating and losses
 - II. Voltage management (static and dynamic)
 - III. Fault level
 - IV. Power quality
 - V. Protection
 - VI. System issues for National Grid
 - Transient stability
 - exporting Grid Supply Points
 - balancing, etc.
 - VII. Security of Supply – ENA Engineering Recommendation P2/6
-

Curtailment for Standard Connections?

Generation connected under firm arrangements will have a resilient supply, however the majority of DG is connected under non-firm arrangements, so when the network is running abnormally, the generation may need to be switched off.

Typically this occurs due to:

- Unplanned faults (transient, short-term and long term)
- Planned maintenance
- Planned new construction works
- Planned asset replacement

The duration of the abnormal running depends on the criticality of the event and will range from milliseconds to months

Alternative Connections

TIMED



- **Generation curtailed within specific times**
- Sub 1MVA
- Modelled seasonal capacity variations
- Localised control only
- No comms
 - May have for voltage constraint
- Non-optimised

SOFT-INTERTRIP



- **Releases pre-fault capacity with trip facility**
- 11kV and 33kV
- Real-time monitored values
- Small clusters of generation or simple pinch points
- Existing monitoring with localised control

ACTIVE NETWORK MANAGEMENT

1010
1011
0100

- **Fully optimises capacity based on all constraints**
- Management of generation using LIFO principles
- Real-time granular control of output
- Requires new Active Network Management control and monitoring systems

Costs, Complexity & Network Optimisation

Alternative Connections

Traditionally all connection agreements have been in a single format.

| | |
|----------------------------|--|
| Standard Connection | Conventional connection (with CAF, where applicable) |
|----------------------------|--|

Alternative Connections can also be connected under three additional commercial arrangements.

| | |
|--|---|
| Enduring Alternative Connection | Alternative connection (no CAF) |
| Interim Alternative Connection | Alternative until reinforcement complete (CAF) |
| Part Standard, Part Alternative | Increase capacity of existing standard connection with additional Alternative capacity 'top up' |


Trade-offs between Alternative Connections and Conventional Reinforcement

| | Up Front Cost | Ongoing Cost |
|-----------------------------------|---------------------|---|
| Timed connections | Low | Curtailment (fixed by timed restrictions, i.e. 11.3%) |
| Soft Intertrip | Medium | Curtailment (depending on network conditions, and “sub-optimal”) |
| ANM | Medium | Curtailment (depending on network conditions, “optimal” curtailment) Capacity-based subscription fee |
| Conventional Reinforcement | High / Medium / Low | None |

All connections designed as ‘non-firm’ will be switched off for abnormal running

Estimating Curtailment

WPD uses historical load data on its network models and superimposes idealised generation profiles to estimate the level of curtailment experienced by the connections




What Influences Curtailment?

Increase


- Outages for maintenance
- Unplanned Faults
- Load loss
- Net demand transfers out
- Net generation transfers in
- Small scale generation
- Communications loss

Decrease

- New load connections
- Load increases
- Net demand transfers in
- Net generation transfers out
- Generation outages
- Reinforcement
- Accepted generation not materialising



Timed Connection
No comms
Local control
Single generator




French Fm WF Proposed
Connection November 2013


Soft Intertrip (Voltage)

No comms

Local measurement and control

Single generator





ANM (Multiple Constraints)

Comms required

Remote measurement

ANM interface to SCADA

Multiple generators

Where, When and How?

All areas are now issuing basic Alternative Connections, with the most complex types being rolled out in phases.

- **Timed**
 - Available in all areas for non-PV, sub 1MW connections where there is sufficient installed PV to diversify against
- **Soft Intertrip**
 - Available in all areas for generators restricted by a single constraint
 - Maximum of three connections per constraint
- **ANM**
 - Being rolled out in phases to the most complex and oversubscribed areas
 - Active in Skegness (November '13) and Corby (April '14)
 - Due for 9 other areas – Bridgewater/Street (November '14), Horncastle (April '15), Truro (November '15)

Applications are accepted through the normal enquiry process

Consortia Approach

- **Sharing Reinforcement**
 - Allows for consortia application
 - Common reinforcement costs shared
 - Avoids £200/kW capping
- **Developing consortia/agreements**
 - Assessing viability of trial location
 - Seeking options to bring developers together
- **Facilitating sharing of information**
 - Allowing potential partners visibility of other interest



Questions



Lunch


Session 2

Demand Side Response

NEXT GENERATION NETWORKS

Distribution Networks: A Balancing Act
Demand Side Response

Gary Swandells



Agenda

- What is DSR ?
- WPD's trials and results
- What are the UK's other Network Operators doing
- Business as Usual
- What's Next



Demand Side Response

What is DSR ?

It has many names –

- Demand Response (DR)
- Load or Peak Shifting
- Load Curtailment
- Peak Avoidance
- (VPP) Virtual Power Plant

How is DSR provided?

When Instructed -

- Shift or avoid energy consumption
And / Or
- Start or increase the output of local generation.

What can DSR be used for ?

- Support system balancing
 - Reduce stress on networks
 - Energy trading / arbitrage
 - Avoidance of high cost periods
 - Local and National capacity issues
 - Emergency mitigation
 - Replace older, low efficiency and marginal power plants
-


What benefit is it to a DNO ?

- Temporary or transient faults
- Brief or occasional capacity issues
- Ensuring improved network security
- Avoiding or deferring capital investment costs
- Reducing interruptions and durations of outages
- Increasing existing asset utilisation
- Improving value for money to consumers



WPD's trials of DSR

- Seasonal Generation Deployment
- Project FALCON
- SoLa Bristol
- ECHO



WPD's trials of non-domestic DSR

Seasonal Generation Deployment

Creation of a generator storage facility at WPD substation.

Generator hire company to leave summer event generators during winter periods.

Operated by an aggregator who would manage service delivery

- STOR
- Triad
- DNO peak lopping

Objective:

Develop and deploy the engineering interface

Establish commercial arrangement

Create an economic generation control methodology.

aggreko

flexitricity
Unlocking smart grid revenue



WPD's trials of non-domestic DSR

Seasonal Generation Deployment Results

Engineering objectives met.

Physical plinth & connections built.

Control interface developed.

Control strategy agreed.

Commercial arrangements identified programme conflicts between National Grid and DNO requirements.

Insufficient incentive for project partners.

aggreko

flexitricity
Unlocking smart grid revenue



Project FALCON

Flexible Approaches to Low Carbon Optimised Networks

Testing new smart engineering methods as an alternative to conventional reinforcement.

Create new commercial intervention alternatives.

Develop new advanced communications system to operate local 'Smart' network.

Create new network planning tool that intelligently selects the best and most economic method to upgrade networks.



Project FALCON

<http://www.youtube.com/watch?v=2QAbon85yrk>

Project FALCON

- New resources and processes to engage with customers.
 - Author and approve new 'performance based' contracts
 - Engage control room in development of 'use case'
 - Financial approval of business proposition
 - Control room dispatch arrangements
 - Performance assessment software
 - Back office systems for settlement processes
 - Detail the market conflicts and propose any potential solutions
 - Learning (statistical & attitudinal)
-

Project FALCON

Commercial trials season 1 completed

FALCON met all recruitment objectives for **Distributed Generation** trials

- Direct and third party contracts
- Participation of six aggregators, three of which successfully recruited trialist
- In excess of 10MW of capacity from 11 participants
- Small, medium & large capacity generators
- Stand by and CHP
- Diesel & Gas engines

Project FALCON

Commercial trials season 1 completed

Despite several prospects there were no Load Reduction participants

This was not unexpected as it broadly reflected across the majority of DSR programmes and trials



Project FALCON

Commercial trials season 1 results

- 181 potential availability windows
- 61 declaration unavailable
- 66.3% reliability factor

| site | 06-Nov | 11-Nov | 18-Nov | 25-Nov | 02-Dec | 09-Dec | 16-Dec | 23-Dec | 30-Dec | 06-Jan | 13-Jan | 20-Jan | 27-Jan | 03-Feb | 10-Feb | 17-Feb | 24-Feb |
|------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 |
| 1 | N | N | N | N | Y | Y | N | N | N | Y | Y | Y | Y | Y | Y | Y | Y |
| 2 | N | N | Y | N | N | N | N | N | N | N | N | N | N | N | N | Y | Y |
| 3 | N | N | Y | N | Y | Y | N | N | N | Y | Y | Y | Y | Y | Y | Y | Y |
| 4 | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |
| 5 | N | N | N | Y | Y | Y | N | N | N | Y | Y | Y | Y | Y | Y | Y | Y |
| 6 | N | N | N | N | N | N | N | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 7 | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 8 | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 9 | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | N | N | Y | Y |
| 10 | Y | Y | Y | Y | N | N | N | N | N | N | N | N | Y | Y | Y | Y | Y |
| 11 | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |

Commercial trials season 1 results

- 18 Events called between 27th November & 28th February
- Approximately ¼ GWh of generation for purposes of trial
- Relatively small number of incidents of delivery failure
- DNO DSR programme conflicts with National Grid Balancing Service

DSR Shared Services Group

- Without sharing framework its unlikely DNO will use DSR as conflicts inflate cost beyond justifiable levels.
 - Representation by National Grid & all UK DNOs
 - Identify any conflicts and synergies between likely services
 - Contractual arrangements
 - Operation
 - Systems
 - Propose a high level sharing framework
 - Publish a consultation with findings and proposals
-

DSR Shared Services Group Highlights

- Primary conflicts contractual based on STOR exclusivity
 - Asset sharing presents better value to consumers
 - Increases choice to participants without mandating multi-use
 - Addresses the risk of unnecessary inflation resulting from exclusive access
 - National Grid's requirement is 'non-geographic' and in majority of circumstances have multiple options with only marginal cost impact.
 - Geographical sensitivity can make DNO requirement more acute with little or no redundancy for low voltage constraints
 - Access rights to assets determined by time separation
-

Project FALCON

Season 2

- Week ahead notification of operating schedule
 - Capped consumption target based on previous year's peaks
 - New back office systems
 - Increased incentive for load reduction
 - Additional aggregator involvement
 - Data from new Smart Meter solution
-

Post Trial - Business as Usual

DSR justified on the bases of managing;

- Transient and temporary pre-fault constraints
- Post-fault restoration of supplies
- Reduction of risk while establishing investment case or awaiting planned capital upgrades

WPD will seek to develop services during 2015 for use during ED1

- Where we might want these services?
 - How often we would want these services?
 - How long we might want these services?
 - How much it could be worth?
 - What is our offer going to look like, how will we select these services?
 - What could count as DSR?
 - Methods of dispatch of DSM/DSR?
-

Questions



Session 3


Energy Storage

NEXT GENERATION NETWORKS

Distribution Networks: A Balancing Act Learning from Energy Storage Projects

Mark Dale


Innovation & Low Carbon
Networks Engineer




Project FALCON Energy Storage Findings

- Optimum locations on a DNO system and locating sites
 - Supply, delivery and installation challenges
 - Integration of the system and controls
 - Acoustic protection and monitoring
 - Charging regime and discharge triggers
 - Peak shaving
 - Potential commercial opportunities for asset owners
-


Initial Learning – peak shaving (24 hours)



Initial Learning – peak shaving (week)



Initial Learning – frequency regulation (9 hours)



Presentation Outline

- Brief Overview of Sola Bristol
 - Time of use Tariff
 - Charging Envelopes
 - Customer Engagement
-

Project Aims

- To solve the network problems which arise when a number of customers in a local area connect PV solar panels to their house
 - Investigate how a battery installed in the home can help customers to manage their energy usage and save money on their bills
 - Test how consumers respond when offered different electricity tariffs throughout the day
 - Explore the benefits of supplying electricity by direct current (DC), rather than the traditional alternating current (AC) and the impact on power quality.
-

Project Partners

Bristol City Council

Deploying technology at their sites, engaging with schools and offices



Knowle West Media Centre

Leading the domestic properties engagement



Siemens

Designing and providing technology for the project




University of Bath

Academic partner, Knowledge dissemination, tariffs and design



What we are capturing

- Bath Repository
- Sub-Stations 11
LV Network Manager
- Domestics 26
LV Connection Manager
- Schools 5
- Commercials 1
- DC Load types
 - LED lighting
 - Laptop/Desktop



Integrating

- Distributed Solar-PV
- DC storage / DC micro-grid

Enabling

- On-demand export to grid (Tariff/Voltage/Thermal/Surplus)
- Load shifting from AC to DC
- DC lighting & computing
- Partial grid independence
- Sub-station monitoring



SoLa Bristol Domestic Variable Tariffs

Lessons learnt

1. The vast majority of our project participants find electricity concepts complex, including the term kWh.
2. The more effective the variable tariff, the more complex it is to both explain and operate.

Selection of variable tariffs

All popular types of variable tariffs reviewed,

A Real-Time Pricing (RTP) tariff was selected as the basis for the SoLa Bristol domestic Variable Tariff,



It was noted that such tariffs are difficult for customers to understand,

The total benefit obtained from PV generation and battery charging will be expressed to customers as a discount on a fixed tariff, which could be as much as 2.5p/kWh. The greater the benefits of peak lopping and avoided network reinforcement, the bigger the discount could be.




Real-time price profile plotting

8 scenarios: winter, spring, summer & autumn,
--weekdays & weekends.



Optimising the use of battery storage for both customers and DNOs

The SoLa Bristol - LV Connection manager (in home intelligence) optimises the use of the batteries for both the customer and the DNO through the use of battery charging envelopes.



Battery charging envelopes comprise of both the minimum and maximum state of charge available to the LV Connection manager any time.

Key Characteristics

- initial state of charge,
- charging/discharging rates,
- charging/discharging start time,
- duration
- slopes


Battery Charging Envelopes – How they are used

- When the DNO has no network constraints
- When the DNO experiences Voltage or Thermal constraints
- How Charging envelopes change

Early Learning from domestic Data



In House 19 we have seen the domestic load remain abnormally high during the day. The target & minimum SOC 50% and 20% were not high enough to support the battery volts during the evening peak period.

H19 7 Oct - 9 Oct 2014



School Settings (Test Bed)

Set up to allow high DC load during the day to be supported by the battery



Customer Engagement Issues

- 30 customers required, but chosen primarily by the position of their roof
- Access difficulties, Installations typically take 2 -3 days plus commissioning
- High Poverty and unemployment area- certain amount of apathy and lack of interest in project goals – What's in it for me?

“I haven’t used the tablet for months as it has never worked properly... but since May I’ve been saving at least £5 a week on electric. I used to put on £60 a month and now put on £40.” House 18

**“I look at the tablet almost every day now and it’s quite useful,”
House 06**

**“When they disconnected the solar panels to put the box in I noticed our energy use went right up – so it’s definitely saving us.”
House 10**

Participant Feedback

“Our power went off as the meter had run down but we didn’t realise as the lights were still on... It shows the panels are saving us.” House 30

**“ I’ve never managed to see anything on the tablet. It only worked for a short time. I’ve always been a low user, so haven’t seen much difference.”
House 21**

NEXT GENERATION NETWORKS


Distribution Networks: A Balancing Act

A DG Developer's Perspective


British Solar Renewables

Steve Edwards

Technical Director



Thomas Alva Edison, 1931



Jay Brannan
© 2018

British Solar Renewables

- BSR generates clean energy.
- We've delivered circa 200MWp since our launch in 2010.
- We finance, design, build & operate large scale solar parks, commercial and agricultural roof mounted arrays
- JV with Siem Industries Inc., a €7bN global diversified industrial group



The UK market for power is changing rapidly

| Old World | New World |
|--|---|
| Predictable central generation, direct management of capacity | Controlled, predictable central generation Less predictable, uncontrolled distributed generation |
| Annual demand growth ~ GDP | Annual demand growth >> GDP |
| Predictable network load | Unpredictable swings in local network load |
| Low volatility | Rising volatility |



Combined with Distributed Generation, Storage has enormous potential

- PV is already deployed at scale, connected at or near demand
- Solar generation is predictable, but leaves almost 90% of connection capacity unused
- Combining PV with storage gives DNOs an alternative to wholesale reinforcement
- Network volatility needs a local rather than a centralised solution



The UK has 20GW of renewable generation installed

- 10GWp of Wind deployed
 - - 70% on-shore
- 5GWp of Solar deployed
 - - growing to 8GW by Q2 2015
 - - 100% on-shore, near areas of demand




DECC's own figures demonstrate that PV power is very predictable

- PV generation is very predictable
 - Variation between installations is very low
 - Average Capacity Factor is similar to Wind, micro-CHP
 - Inter-year variation very low

- Predictability makes large scale integration far easier

Load factor and range for technologies installed under FIT




| FIT data | Installations to 2011 / 12 | Generation / MWhr 2011 / 12 |
|-----------|----------------------------|-----------------------------|
| Solar PV | 39,715 / 295,378 | 12.4 / 109.1 |
| All other | 2,023 / 3,804 | 0.8 / 1.7 |

PV is summer-biased, but always contributes a base load

- Peak generation is mid-day and mid-summer
- However monthly generation never drops below 25% of maximum ...
- ... and is on average 67% of monthly maximum


**Monthly Irradiation –
Butleigh, Somerset**



Grid linked PV only uses a fraction of its network capacity


- Grid-connected PV almost never uses the full capacity of its connection
- Half of the time only half of that capacity is being used
- The opportunity for storage is to use more of that capacity to import and to export

**Grid connected PV
Network connection
capacity**



Storage can benefit developers by expanding DC capacity


- Stores energy for export when most valuable
- Allows greater DC capacity to be connected per MW of grid capacity



Installing storage would fix short-term variability in export





- Short-term variation in export is due to clouds
- Connection protocols protect the network but limit PV deployment
- Export smoothing would allow more PV onto sensitive networks

Chilton Cantelo 5MW
Generation 2 – 8 October '14



Storage can also help to address local or national volatility

Settled price per MWhr vs Time of Day
20011 – 2014 (by month)




We will install storage on 1.5MW PV array with storage at our head offices in Somerset

- Techno-economic trial of a real battery energy storage system on a large solar generator's side of the meter, in Somerset.
- Quantify benefits for both the DNO and Customer with real data.
- WPD South West & 3 other project partners:



- What will be the benefits of generator connected storage?
 - Generator earnings and project viability.
 - Network management services.
- Explore routes to market – challenges and rewards.
- Making the case for energy storage in new connection offers.

System schematic



Outputs of the project are designed to guide design, commercial arrangements and legislation

- The first commercial demonstration of Solar Integrated storage in the UK
- LCNF funded by Western Power Distribution, Elexon and NSC review
- Demonstrates at scale all of the modes in which storage and PV create value

| Usage Case | Benefit |
|---|---------|
| Sell electricity for a higher price per kWh | Owner |
| Shape generation profile to demand | DNO |
| Peak lop network demand (by exporting) | DNO |
| Raise minimum demand to limit voltage rise | DNO |
| Voltage control | DNO |
| Peak lop generation to build bigger solar parks | Owner |
| Smoothing / Power Quality | DNO |
| Change peak lopping level (glass ceiling) | DNO |
| Constructive system interactions | DNO |

Steve Edwards
Technical Director
British Solar Renewables

Steve.Edwards@Britishsolarenewables.com

01428 244900




NEXT GENERATION NETWORKS

Distribution Networks: A Balancing Act
Identifying energy storage opportunities
- a DNO's point of view

Philip Bale

Innovation & Low Carbon
Networks Engineer



Energy storage - A DNO's considerations

1) Energy Storage - a “Black Box”


- Where could energy storage be located? What size should it be? The pro's and con's.
- How to model 3rd party energy storage?

2) The “Functional Specification” for Energy Storage as an alternative to conventional network reinforcement.

- The study assumptions,
- Analysis – Two demand scenarios,
- Analysis – Two standard generation scenarios, and
- The opportunities of using energy storage in Active Network Management areas to reduce constraints for generators.

3) Summary & Other considerations.

- Ownership models and regulatory restrictions,
 - The benefits of whole network thinking and further analysis required.
-



<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=017db2b692&e=7f8c272bc0>

- September 5th, 2014

<http://cleanhorizon.us5.list-manage1.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=c65a3cbb4b&e=7f8c272bc0>

- September 12th, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=7da7a3b82a&e=7f8c272bc0>

- September 19th, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=8794fe809d&e=7f8c272bc0>

- September 19th, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=dfb6805973&e=7f8c272bc0>

- September 25th, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=33b7b49eaf&e=7f8c272bc0>

- October 3rd, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=d42c8e6ebd&e=7f8c272bc0>

- October 3rd, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=6a14064f62&e=7f8c272bc0>

- October 10th, 2014

<http://cleanhorizon.us5.list-manage1.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=13e77194b7&e=7f8c272bc0>

- October 10th, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=ea47619411&e=7f8c272bc0>

- October 16th, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=ed75ff558c&e=7f8c272bc0>

- October 30th, 2014

<http://cleanhorizon.us5.list-manage2.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=1ece2390c4&e=7f8c272bc0>

- October 16th, 2014

<http://cleanhorizon.us5.list-manage.com/track/click?u=c8fe16f28bd08d9c7858b5a33&id=b03e6bef1f&e=7f8c272bc0>

- November 6th, 2014

Assumptions

- Steady state studies analysis using IPSA & Excel have modelled power flows using both ½ hourly SCADA data and LTDS weather normalised data.
- Demand studies have been conducted at sites reinforced during DR5.
- Case Studies have only assessed networks Classed as type B & C under Engineering Recommendation - P2/6 Planning minimum network security.
- Historic network demand has been scaled using three of National Grids “UK Future Energy Scenarios¹” to assume changes in peak and off peak demands:
 - **No Progression** - 3.5% reduction in demand between the hours of 4pm and 8pm. A 2.2% decrease in demand for the remaining hours.
 - **Low Carbon Life** - 8.3% increase in demand between the hours of 4pm and 8pm and 8.1% increase in demand for the remaining hours.
 - **Gone Green** - 12.5% increase between the hours of 4pm and 8pm and 6.1% increase for the remaining hours.
- Demand studies assume no contribution from current or future embedded generation
- Studies assume longest credible outage during the most onerous period.
- There may be opportunities to reduce the installed Energy Storage MWh by a DNO combining Energy storage with mobile generators, DSM and/or agreeing to a greater level of risk for sustained outages.
- Generation studies have used anonymised real generation data for large scale wind and solar PV Generators.

¹ Available at: <https://www.gov.uk/government/publications/updated-energy-and-emissions-projections-2013> [Accessed 28 August 2014].

Fiskerton Primary substation


- What is the issue?
- How could energy storage alleviate constraints between now and 2035?
- When might it be required, when would we not require energy storage, and
- What is the alternative and how much does it cost.



| Scenario | Power (MW) | Capacity (MWh) |
|-----------------|------------|----------------|
| No Progression | 2.6 | 6 |
| Low Carbon Life | 4.25 | 13 |
| Gone Green | 4.75 | 17 |

| ITEM | COST |
|----------------|--------|
| P + M | ≈£700k |
| Civil | ≈£30k |
| Cable jointing | ≈£50k |
| Total | ≈£800k |

Fiskerton Primary Peak Demand




Hucknall Primary substation.

- What is the issue?
- How could energy storage alleviate constraints between now and 2035?
- When might it be required, when would we not require energy storage, and
- What is the alternative and how much does it cost.



| ITEM | COST |
|---------------------------|--------|
| Plant and Materials (P+M) | ≈£100k |
| Cable works | ≈£3m |
| Total | ≈£4m |

Hucknall Primary Peak Demand



| Scenario | Power (MW) | Capacity (MWh) |
|-----------------|------------|----------------|
| No Progression | 3.1 | 42 |
| Low Carbon Life | 5.5 | 79 |
| Gone Green | 6 | 67 |

Wind Farm & PV Farm - conventional connections

- What is the issue?
- How could energy storage alleviate constraints
- When might it be required, when would we not require energy storage, and
- What is the alternative and how much does it cost.

12.5MW Wind Farm Connection
Northamptonshire

Period of minimum demand 7th Sept – 13th Sept
2013

Energy Storage requirements

- Maximum sustained power rating: 7.5 MW
- Useable capacity: 988.7 MWh+

Conventional Network Reinforcement

| Item | Costs |
|-----------------------|--------|
| Fees | ≈£10k |
| P + M | ≈£300k |
| Cable works | ≈£7m |
| Overhead construction | ≈£800k |
| Total | ≈£8.3m |

12MW Solar PV Farm Connection
Northamptonshire

Period of minimum demand 20th Jun 2013 – 26th
Jun 2013.

Energy Storage requirements




- Maximum sustained power rating: 6 MW
- Useable capacity: 20 MWh

Conventional Network Reinforcement

| Item | Costs |
|-------------|--------|
| Fees | ≈£10k |
| Cable works | ≈£100k |
| Substation | ≈£250k |
| Total | ≈£350k |

DG – ANM connections

- What is the issue?
- How could energy storage alleviate constraints , and
- When might it be required, when would we not require energy storage.



| GSP Group | Active BSP Group | Quoting form | Building during |
|---------------|----------------------|--------------------------------|--------------------------------|
| Bicker fen | Skegness | Active | Active |
| Grendon | Corby Northampton | Active April 2016 | April 2015 April 2017 |
| Bridgwater | Bridgwater Street | November 2014 November 2014 | November 2015 November 2015 |
| West Burton | Horncastle | April 2015 | April 2016 |
| Indian Queens | Truro | November 2015 | November 2016 |
| Swansea North | Swansea Pembroke | November 2016 November 2016 | November 2017 November 2017 |

Energy Storage :-

- Could be considered as a “black box”,
- No one size fits all,
- Requirement for whole system thinking,
- CBA could be location specific, both for a DNO and other revenue streams (STOR, Fast Reserve, frequency response.....),
- Additional revenue streams & opportunities may exist in some Active Network Management areas.

Why a DNO would want to use Energy Storage as an alternative to Conventional Network Reinforcement?

The current limitations that could prevent a DNO from using Energy Storage as an alternative to Conventional Network Reinforcement.

All DNOs are working together to share learning from all projects & trials in the form of a Good Practice Guide – December 2014.



Distribution Networks: A Balancing Act

WPD believes opportunities already exist to better balance generation and demand.

- **Alternative Connections**

- Business as Usual - Timed, Soft-Intertrip and ANM in selected areas,
- A roadmap for 11 ANM zones across WPD by 2018,
- Further opportunities will continue to be explored.

- **Demand Side Response**

- Clear post trials road map outline for ED1.

- **Energy Storage**

- Currently, WPD has no plans for WPD to fund Energy Storage in ED1,
 - However, there are currently a number of key variables which with further maturity could result in Energy Storage being used as an alternative to Conventional network reinforcement in certain circumstances.
-

Questions



www.westernpowerinnovation.co.uk

wpdinnovation@westernpower.co.uk