

Company Directive

ENGINEERING SPECIFICATION EE SPEC : 16/8

LV Distribution Fuseboards

Policy Summary

1. This specification details requirements for LV Distribution Fuseboards for use on Western Power Distribution's distribution system.
2. The specification is based on EA Technical Specification 37-2. (Issue 5, 2012)
(Public Electricity Network Distribution Assemblies) (PENDA)

Author: Stephen Hennell

Implementation Date: January 2018

Approved by:

Policy Manager

Date:

10 January 2018

NOTE: The current version of this document is stored in the WPD Corporate Information Database. Any other copy in electronic or printed format may be out of date. Copyright © 2018 Western Power Distribution

IMPLEMENTATION PLAN

Introduction

This document revises the existing WPD specification and provides for future requirements.

Main Changes

Introduction of an option for current transformers on each outgoing feeder way for future load monitoring and LV network control purposes. WPD Type References have been revised for ease of specifying. Additional standard types have been introduced.

Impact of Changes

No direct impact on current application/use of this equipment.

Implementation Actions

Specification EESPEC 16/7 is to be withdrawn on release of this revised version.

Purchasing to utilise this revised specification for establishing a new purchasing contract.

Plant Centres to note.

Implementation Timetable

This revised document may be implemented immediately for the purpose of tender and establishing a revised Framework Contract.

Revision Log

Document Revision & Review Table		
Date	Comments	Author
January 2018	<ul style="list-style-type: none">• Introduction of an option for current transformers on each outgoing feeder way for future load monitoring and LV network control purposes.• WPD Type References have been revised for ease of specifying.• Additional standard types have been introduced.	S. Hennell

1.0 SCOPE

This specification covers fuseboards of a shielded pattern with insulation to shield operators and others working on the equipment against inadvertent contact with live components of the following types:-

- (i) PENDA-I – Substation Cable Distribution Board - Indoor. WPD designation - IFB.
- (ii) PENDA-CCO - Substation Cable Distribution Board - outdoor ground mounted pillar. WPD designation - FP.
- (iii) PENDA-TMO - Substation Cable Distribution Board - outdoor transformer mounted fuse cabinet. WPD designation - TMC.

2.0 INTRODUCTION

All equipment supplied under this specification will meet the technical requirements of EA Technical Specification 37-2– Issue 5 2012 – Public Electricity Network Distribution Assemblies - a copy of this specification is given in Appendix A.

Clauses contained within this specification are in addition to the requirements of EA Technical Specification 37-2. Where there is any conflict between EA Technical Specification 37-2 and this document, this document shall take precedence.

3.0 TYPE AND DESIGN

3.1 General

- 3.1.1 The range of WPD standard equipment required is detailed in Table 1a, Table 1b and Table 2 of this specification. Alternative equipments, to this standard, shall be as specified at time of purchase.
- 3.1.2 A Circuit Breaker as specified in clause 3.3 shall be suitable for terminating 8 x 600/740mm² "SOLIDAL" or 630mm² Copper armoured single core cables.
- 3.1.3 All equipment shall be supplied complete with bolts, washers, nuts and spring washers to make the connection between the cabinet and the transformer where applicable.
- 3.1.4 All neutrals on equipment supplied to WPD shall be full sized i.e. the same current rating as the corresponding phases.
- 3.1.5 A fully rated bolted link shall be provided for disconnection of the neutral.
- 3.1.6 All outdoor equipment shall be designed to allow water shedding from all surfaces and prevent any accumulation of water or wind-borne materials.

- 3.1.7 All outdoor equipment shall have a surface preparation and coating system inline with Scheme 4 of ENATS 98-1 ie. 10-20 years to first maintenance in an exposed polluted coastal environment.
- 3.1.8 All transformer mounted cabinets shall be supplied with deep doors in order to readily accommodate a future LV automation device or monitoring equipment.
- 3.1.9 All equipment shall be supplied complete with shear-off type connectors for making outgoing cable connections to 630amp fuseways where applicable.
- 3.1.10 All equipment shall be supplied with bolts, washers, nuts and spring washers to make the connection between a circuit breaker and the outgoing "SOLIDAL" cables where applicable.

3.2 Short Circuit Rating (3 second)

- 3.2.1 Equipment of 800A or below shall have a short circuit rating of 18kA and equipment above 800A shall have a short circuit rating of 35.5kA as detailed in Table ENATS3 of ENATS 37-2 irrespective of transformer size.
- 3.2.2 3150A equipments shall have a short circuit rating of 50.0kA

3.3 Specification of Circuit breaker

- 3.3.1 Minimum rated service short circuit breaking capacity (I_{cs}) shall be 35.5kA. Minimum rated short time withstand current (I_{cw}) shall be 20kA for 1 second. Rated Current for the circuit breaker shall be 800A, 1250A or 1600A as determined by the unit type.
- 3.3.2 The mechanism shall be dependent manual.
- 3.3.3 The circuit breaker shall be suitable for providing a point of isolation.
- 3.3.4 The unit shall be Utilisation category B. (As outlined in BS EN 60947-2 Clause 4.4 – Table 4).
- 3.3.5 The ratings of the circuit breaker shall be when the circuit breaker is fitted in the cabinet / pillar / distribution board and the whole assembly subject to temperature rise test as detailed in clause 10.10 of ENATS 37-2. (Verification of temperature rise limits).
- 3.3.6 The circuit breaker shall be equipped with integral, adjustable, phase fault protection with characteristics and setting ranges specified below:
 - Overload characteristic, adjustable between 0.5 x and 1.0x circuit breaker Rated Current (at least 5 steps).
 - I^2t characteristic with time settings adjustable between 1 and 20s at 6x the overload setting (at least 4 steps).

- A short time characteristic, selectable between definite time and I^2t with current setting adjustable between 2x and 8x overload setting (at least 5 steps) and with time setting adjustable between 0 and 0.4s (at least 4 steps).
- An instantaneous characteristic with current setting adjustable between 2x and 10x the circuit breaker Rated Current (at least 5 steps).

In addition to phase fault protection, 1600A circuit breakers shall be equipped with residual earth fault protection satisfying the following requirement:

- Earth fault characteristic selectable between definite time and I^2t with current setting adjustable between 600A and 1200A (at least 5 steps) and with time setting adjustable between 0 and 0.4s (at least 4 steps).

The circuit breaker shall have a 240V 50Hz shunt trip coil and auxiliary switch.

A facility must be provided to lock the circuit breaker in the open position with a padlock. This locking arrangement shall meet the requirements of Clause 8.201.c of ENATS 37.2

The circuit breaker must comply with BS EN 61000 – Electromagnetic Compatibility (EMC).

3.4 **Indoor Fuseboards and Fusepillars only**

3.4.1 For indoor fuseboards the design shall permit the use of incoming insulated bars or cables as follows:-

- 1600A units suitable for either 8 or 12 cables
- 1250A units suitable for 8 cables
- 800A units and below suitable for 4 cables

3.4.2 The arrangement of the incoming and outgoing units shall be suitable for cables approaching from below. In the case of indoor fuseboards, however, the design shall be such that the cable support bar can be refitted on site so that the transformer connections and/or distributor cables may approach from either below or above.

3.4.3 The palms to accept the compression lugs or mechanical connectors on the ends of the incoming cables shall be drilled with 4 holes drilled in accordance with Figure 16 of BS2562:1979

3.4.4 Bolts, nuts, locknuts and washers to secure the lugs and connectors to the palms on the transformer unit shall be provided, but lugs or connectors are not to be supplied. (Provision shall be made for the palm on the lug or connector having a minimum thickness of 13mm).

3.4.5 The copper connections between the transformer terminals and the transformer isolator in the pillar shall be made in bolted sections so that they can be re-arranged on site to give any desired sequence of phase connections to the busbars.

3.5 **Generator Connection**

- 3.5.1 Provision for connecting a generator shall be provided, with all units except the outdoor feeder pillar design.
- 3.5.2 The connection from the transformer side to the synchronising reference fuses shall be double insulated and of not less than 16mm².
- 3.5.3 Female 'Litton' connectors (or equivalent) shall be provided on each busbar and the neutral/earth bar to allow the safe connection of generator cables onto live PENDA's. Two connectors shall be provided for each phase and neutral on equipments with 1600A or greater busbar rating. One connector shall be provided for each phase and neutral on equipments with 800A busbars. Each connector shall be rated at 600A.
- 3.5.4 Evidence of temperature rise tests shall be supplied at the time of tender with all the generator cables carrying the full 600A current and the adjacent outgoing ways arranged to obtain current balance.
- 3.5.5 The cabinet/pillar doors shall be able to be closed and locked with the generator cables connected.

3.6 **Auxiliaries**

- 3.6.1 The phase connections to the auxiliary fuses from the busbars shall be insulated or fully shrouded copper strap of not less than 75mm².
- 3.6.2 All PENDA-CCO and PENDA-TMO's shall be fitted with a guarded internal light with an on/off switch.
- 3.6.3 For hot sites the provision of an optional isolation transformer will be required.

3.7 **Cables**

- 3.7.1 Where 'SOLIDAL' cables are to be terminated on one of the outgoing circuits, holes drilled in accordance with Figure 16 of BS2562:1979, to accommodate mechanical connectors shall be fitted.

The connectors are not to be supplied, but bolts, nuts, washers and lock washers are to be supplied. Provision should be made for the connector to have a palm thickness of 13.2mm and no offset.

A means shall be provided for supporting the cables. For feeder ways this shall be a cleat or clamp arrangement suitable for the range of cable sizes to be terminated.

Where aluminium wire armoured singles cables are utilised then a suitable non-ferrous gland plate or cable support arrangement shall be installed. This arrangement shall provide for the armour wires of the singles cables to be connected together and independently connected as a group to earth to permit the earthing and bonding requirements of SD5E Figures 8 to 14 to be met.

The gland plate shall be pre-drilled to accept 4, 7 or 8 glands with grommets provided to blank off holes that are not required. [See Table 3 & Table 4]

- 3.7.2 The neutral/earth busbar connection for each outgoing distributor cable shall be at least as Clause 8.201.d (Neutral and Earth Connectors) of ENATS 37-2, but the bolt being long enough to accept a lug with a 12mm thick palm and full washer/nut/lock nut.

3.8 **Current Transformers**

- 3.8.1 A current transformer shall be provided within each phase of the incoming transformer disconnecting unit for operation of a maximum demand indicator. Ratios are as detailed in Table 1. Details of the maximum demand indicator are outlined below.
- 3.8.2 When requested a current transformer ratio 500/5, 2.5VA output and Class 0.5S accuracy, of a design supplied by the manufacturer, shall be fitted to all 3 phases of each outgoing distributor unit of transformer mounted fuse cabinets. Current transformers shall have a thermal rating that matches the rating of the outgoing distributor unit.
- 3.8.3 The secondary connections of each CT shall be brought out to an accessible terminal block, preferably within the unit.

Where this is not practicable then the connections shall be brought out to an external box mounted on the left hand side of the PENDA. This box shall be designed and manufacturer to the same specification as the PENDA housing, have a hinged padlockable door.

Any connections within the CT wiring shall be made at an accessible terminal block.

The terminal blocks shall have integral CT shorting links.

The terminal box shall have a suitable gland plate for the termination of multicore cable.

3.9 **Rogowski Coil**

Where current transformers are not requested on outgoing ways then the facility shall be provided to fit a Rogowski coil to each phase of each outgoing way with the cabinet live and the outgoing fuses fitted. The facility shall be able to accept a flexible probe of up to 8mm diameter.

4.0 MAXIMUM DEMAND INDICATORS

- 4.1 A suitable device, as below, capable of displaying at least Maximum Current integrated over a 30 minute period. The Meter shall be capable of displaying currents from 0 to the maximum values identified in Table ENATS1, without re-selection of scale. The instrument may display three-phase current, or be capable of switching between phases.
- 4.2 The maximum demand measuring instrument may utilise conventional or non-conventional (i.e. electronic) design components which shall provide a high level of security and reliability and should have an anticipated asset life commensurate with the primary equipment.
- 4.3 In cases where the measuring instrument or its sub-components have an anticipated asset life of less than the primary equipment (taking account of its operating environment) then the equipment shall be designed to be physically interchangeable.
- It shall be possible to safely replace the instrument without affecting the IP rating of the primary equipment and without requiring to access live parts. Secondary screening behind the instrument panel shall be provided to enable the maximum demand indicator to be changed with the cabinet live.
- It shall be possible to change the instrument whilst ensuring that CT secondary circuits are not open-circuited.
- 4.4 If the measuring device utilises batteries then it shall be possible to change the batteries without any intrusive work and with the primary equipment in service. The manufacturer shall declare the frequency for replacing the batteries.
- 4.5 The device shall be driven by suitable current transformers, and be rated at 1A or 5A.

Table 1a - Arrangements of Transformer Mounted Fuse Cabinets

WPD Type	TMC 16/5/-	TMC 16/4/-	TMC 08/4/-	TMC 16/7/-
Previous WPD Designation	IX	VII	V	III
ENA Type Designation	PENDA-TMO1	PENDA-TMO2	PENDA-TM03	N/A
Transformer size (Max)	1000kVA	1000kVA	500kVA	1000kVA
Transformer type (ENA Technical Specification 35-1)	Unit / Cable connected	Unit / Cable connected	Unit / Cable connected	Unit / Cable connected
Current rating of busbars and incoming transformer unit	(a) phases	1600A	1600A	800A
	(b) neutral	1600A	1600A	800A
Type on incoming transformer unit	Disconnector	Disconnector	Disconnector	Disconnector
No. and size of outgoing distributor units	Fuseway	5 x 630A	4 x 630A	4 x 630A
	MCCB	-	-	-
Transformer flange to Fig. 25 BS2562	F	F	F	F
Deep door	Yes	Yes	Yes	Yes
Current Transformer ratio – one per phase – incoming transformer circuit	1600/800/5	1600/800/5	800/400/5	1600/800/5
MDI – one indicator per phase – incoming transformer unit	(a) Scales	0-1920A 0-960A	0-1920A 0-960A	0-960A 0-480A
	(b) minimum scale marking	320/160A	320/160A	160/80A
Maximum Dimensions				
External width of enclosure body	760mm	610mm	610mm	1060mm
Height from centre line of truncking				
(i) to top of enclosure	460mm	460mm	460mm	460mm
(ii) to bottom of enclosure	1270mm	1270mm	1270mm	1270mm
Number of Generator Connections	2 sets	2 sets	1 set	2 sets

Table 1b - Arrangements of Transformer Mounted Fuse Cabinets with Circuit Breakers

WPD Type	TMC 16/2/CB8	TMC 16/4/CB8	TMC 16/2/CB12	TMC 16/4/CB12	TMC 16/-/CB16	TMC 16/-/2CB8
Previous WPD Designation	XIII	-	XIV	-	XV	XVI
ENA Type Designation	N/A	N/A	N/A	N/A	N/A	N/A
Transformer size (Max)	1000kVA	1000kVA	1000kVA	1000kVA	1000kVA	1000kVA
Transformer type (ENA Technical Specification 35-1)	Unit / Cable connected	Unit / Cable connected	Unit / Cable connected	Unit / Cable connected	Unit / Cable connected	Unit / Cable connected
Current rating of busbars and incoming transformer unit						
(a) phases	1600A	1600A	1600A	1600A	1600A	1600A
(b) neutral	1600A	1600A	1600A	1600A	1600A	1600A
Type on incoming transformer unit	Disconnecter	Disconnecter	Disconnecter	Disconnecter	Disconnecter	Disconnecter
No. and size of Fuseway outgoing distributor units	2 x 630A 1 x 800A	4 x 630A 1 x 800A	2 x 630A 1 x 1250A	4 x 630A 1 x 1250A	- 1 x 1600A	- 2 x 800A
Transformer flange to Fig. 25 BS2562	F	F	F	F	F	F
Deep door	Yes	Yes	Yes	Yes	No	No
Current Transformer ratio – one per phase – incoming transformer circuit	1600/800/5	1600/800/5	1600/800/5	1600/800/5	1600/800/5	1600/800/5
MDI – one indicator per phase – incoming transformer unit						
(a) Scales	0-1920A 0-960A	0-1920A 0-960A	0-1920A 0-960A	0-1920A 0-960A	0-1920A 0-960A	0-1920A 0-960A
(b) minimum scale marking	320/160A	320/160A	320/160A	320/160A	320/160A	320/160A
Maximum Dimensions						
External width of enclosure body	750mm	1100mm	750mm	1100mm	750mm	750mm
Height from centre line of trunking						
(i) to top of enclosure	460mm	460mm	460mm	460mm	460mm	460mm
(ii) to bottom of enclosure	1270mm	1270mm	1270mm	1270mm	1270mm	1270mm
Number of Generator Connections	2 sets	2 sets	2 sets	2 sets	2 sets	2 sets

Table 2 - Arrangements of Outdoor Feeder Pillars and Indoor Fuseboards

WPD Type	OFP 08/3/-	OFP 08/5/-	OFP 16/6/-	OFP 16/10/-	IFB 16/7/-	IFB 16/10/-
Previous WPD Designation	FP3	FP5	-	-	IFB7	-
ENA Type Designation	N/A	N/A	N/A	N/A	N/A	N/A
Transformer size (Max)	N/A	N/A	N/A	N/A	N/A	N/A
Transformer type (ENA Technical Specification 35-1)	N/A	N/A	N/A	N/A	N/A	N/A
Current rating of busbars	800A	800A	1600A	1600A	1600A	1600A
Current rating of incoming transformer unit						
(a) phases	630A	630A	1600A	1600A	1600A	1600A
(b) neutral	630A	630A	1600A	1600A	1600A	1600A
Type on incoming transformer unit	1 x 630A Solid Link	2 x 630A Solid Links	Solid Link	Solid Link	Solid Link	Solid Link
No. and size of outgoing distributor units	3 x 630A	5 x 630A	6 x 630A	10 x 630A	7 x 630A	10 x 630A
Transformer flange to Fig. 25 BS2562	N/A	N/A	N/A	N/A	N/A	N/A
Current Transformer ratio – one per phase – incoming transformer circuit	None	None	1600/800/5	1600/800/5	1600/800/5	1600/800/5
MDI – one indicator per phase – incoming transformer unit	None	None				
(a) Scales			0-1920A 0-960A	0-1920A 0-960A	0-1920A 0-960A	0-1920A 0-960A
(b) minimum scale marking			320/160A	320/160A	320/160A	320/160A
Maximum Dimensions						
External width of enclosure body						
Height from centre line of trunking						
(i) to top of enclosure						
(ii) to bottom of enclosure						
Number of Generator Connections	N/A	N/A	2 sets	2 sets	2 sets	2 sets


Table 3 – Numbers of Cable Cores per Circuit Breaker Rating

Cables [Aluminium Tape Armoured]	Circuit Breaker Rating		
	800A	1250A	1600A
600mm ² "Solidal"	4 (1 per ph / 1 neutral)	7 or 8 (2 per ph / 1 or 2 neutral)	7 or 8 (2 per ph / 1 or 2 neutral)
740mm ² Solidal"	4 (1 per ph / 1 neutral)	4 (1 per ph / 1 neutral)	7 or 8 (2 per ph / 1 or 2 neutral)
630mm ² Copper	4 (1 per ph / 1 neutral)	4 (1 per ph / 1 neutral)	7 or 8 (2 per ph / 1 or 2 neutral)

Table 4 - Cable Gland Characteristics

600mm², 630mm² and 740mm² Aluminium Wire Armoured Cables

Gland Kit Reference	Entry Thread mm (A)	Thread Length mm (B)	Hexagon	
			Across Faces mm (C)	Across Corners mm (D)
KA422-58	M50 x 1.5	15	65.5	72.1
KA422-59	M50 x 1.5	15	70.1	77.2



APPENDIX A

ASSOCIATED DOCUMENTATION

ST:SD5E Design of Low Voltage Commercials and Industrial Connections

ENA Technical Specification 37-2 "*Public Electricity Network Distribution Assemblies*"
<\\AVODCS01\DMS\ACROBAT\MA\EE\EE016\EA TS 37-2 I5.PDF>

APPENDIX B

SUPERSEDED DOCUMENTATION

EE SPEC:16/8 supersedes WPD Engineering Specification EE SPEC:16/7 which should be withdrawn from use.

APPENDIX C

KEY WORDS

Fuseboard, Cabinet, Transformer, Pillar, LV (Low Voltage), Fusebox, Fuse, Fuse-links, Fuse-carriers, Disconnecter.