

Connection Site: **Melksham 132kV Substation**

### Part 5 - Materiality & Wider System Limits

The following table sets out the indicative additional Developer Capacity as Materiality Headroom that the User can use as guidance for managing any future Relevant Embedded Power Station applications.

<b>Capacity Limit Summary</b>		
<b>Category of Connection</b>	<b>MW</b>	
Part 1	<a href="#">see summary table</a>	Historic connections (No additions to this section)
Part 2	<a href="#">see summary table</a>	Connections subject to technical conditions
Part 3	<a href="#">see summary table</a>	Subject to interim restrictions on availability and subject to technical conditions
Part 4	<a href="#">see summary table</a>	Generation that can only connect on completion of works to transmission system and subject to technical conditions
<b>Part 5 Materiality Headroom</b>	<a href="#">see summary table</a>	This figure will reduce as Developer Capacity is allocated or increase if projects cancel or disconnect. However, There is no guarantee or assurance that the capacity included in Part 5 will be available or that plant will be able to connect using it.
<b>Total Aggregated Developer Capacity at the site must not exceed this figure.</b>	<a href="#">see summary table</a>	<b>This figure cannot be changed or exceeded without submission of either a Modification Application, Project Progression or Statement of Works</b>
<b>Technical Condition Summary</b>		
<b>Connection Asset Reverse Power Limits</b>  (Usually the SGT at the site, where that SGT is classified as connection)	N/A	Where facilities exist, such as an ANM scheme, to curtail generation in the event of a SGT circuit fault this limit can be raised.
<b>Fault Level headroom</b>	<a href="#">see summary table</a>	Based on the Iron Acton CB 120 three phase Initial Peak break capability limit.

June 2019



<b><i>Voltage</i></b>	See Note	Voltages conditions apply to new generation projects.
<b>Generator Technology</b>	See Note	There is currently no limit on technology change within this GSP Materiality limit.
<b>Comments/Constraints or Additional Restrictions:</b>		
<b>Transferable Capacity (see note below)</b>	<b>0MW</b>	<b>GSP's: N/A</b>

