

Mr Chris Nichol
Primary System Design Engineer
Western Power Distribution (East Midlands) plc
Pegasus Business Park
Herald Way
Castle Donnington
DE74 2TU

Nicola Paton
Head of Customer Service

Nicola.Paton@nationalgrid.com
Direct tel +44 (0)1926 656703
Direct fax +44 (0)1926 656605

www.nationalgrid.com

18 March 2015

For the attention of Mr Chris Nichol

Dear Sir

**Re: Bulk Request for Statement of Works received on 11 February 2015
For 146.5MW of Embedded Generation at Walpole
User Agreement Reference No. A/EME/90/5-12EX(2)**

I refer to your **Request for a Statement of Works** in relation to the possible connection of the above Embedded Generation to your **Distribution System** (the "Project"). The Company started processing this request on 18 February 2015.

We have now undertaken an initial assessment of the significance of the Project and believe the **embedded generation** does not have a significant impact on the **National Electricity Transmission System** (for the avoidance of doubt, such significant impact involves either party in an expenditure of more than £10,000) and would advise you of the following implications:-

- i. Requirement for works on the **National Electricity Transmission System** where such works are not at a **Connection Site**
NO
- ii. Requirement for works to the **National Electricity Transmission System** at a **Connection Site (Grid Supply Point)**
NO
- iii. Necessity for **Site Specific Requirements** (at the site of connection) of the **Power Station**
YES

As a consequence of these connections, Western Power Distribution (WPD) will need to manage and maintain a power factor of 0.95 leading locally on their network when required by National Grid.

National Grid is currently reviewing the wider issues of high voltage across the National Electricity Transmission System and will be seeking to work with WPD going forward to identify potential solutions to high volts in the local area. The output of these studies may recommend reinforcement works on the either the transmission or distribution network..

As this **Statement of Works** does not specify any works as being required as being necessary, our letter completes the process required for in respect of your **Request for a Statement of Works** for the purposes of CUSC Paragraph 6.5.1(a)(i).]

This **Statement of Works** is made on the basis of and is only valid in respect of the information provided by the **User** in the **Request for a Statement of Works**. If the **User** wishes to make any changes to any information submitted with the **Request for a Statement of Works** a new **Request for Statement of Works** must be submitted to **The Company** before **Energisation** of the connection can take place. Please note, you may not energise the connection of the Project without having received a written notification from **The Company** that the process set out in Paragraph 6.5 of CUSC has been complied with in full.

Please note this **Statement of Works** should be forwarded to the **Embedded Generators** as soon as reasonably practicable in accordance with Paragraph 6.5.5.3 of the CUSC.

All communication in relation to this **Statement of Works** should, in the first instance, be directed for the attention of Steph Wootton, who can be contacted by telephone on 01926 656126 or by email at steph.l.wootton@nationalgrid.com

Yours faithfully

NICOLA PATON
HEAD OF CUSTOMER SERVICE

FOR AND ON BEHALF OF
NATIONAL GRID ELECTRICITY TRANSMISSION PLC