

Mr Andrew Akani
Primary System Design Engineer
Western Power Distribution (West Mids) plc
Toll End Road
Tipton
West Midlands
DY4 0HH

Vicky Higgin
Head of Customer Service

victoria.higgin@nationalgrid.com
Direct tel +44 (0)1926 654980
Direct fax +44 (0)1926 656605

www.nationalgrid.com

23rd October 2014

For the attention of Mr David Bennett

Dear Sir

**Re: Request for Statement of Works received on 14th August 2014 for
Multiple Embedded Generators (totaling 116.4MW) at Iron Acton Substation
Ref: A/ME/90/7-10EX(1)**

I refer to your **Request for a Statement of Works** in relation to the possible connection of the above embedded generation to your **Distribution System** (the "Project"). The Company started processing this request on 16th September 2014.

We have now undertaken an initial assessment of the significance of the Project and believe the embedded generators does not have a significant impact on the **National Electricity Transmission System** (for the avoidance of doubt, such significant impact involves either party in an expenditure of more than £10,000) and would advise you of the following implications:-

- i. Requirement for works on the **National Electricity Transmission System** where such works are not at a **Connection Site**
NO
- ii. Requirement for works to the **National Electricity Transmission System** at a **Connection Site (Grid Supply Point)**
NO
- iii. Necessity for **Site Specific Requirements** (at the site of connection) of the **Embedded Generators**
NO

As none of the embedded generators stated in your application individually have generation levels ≥ 50 MW they do not classified as LEEMPS (License Exempt Embedded Medium Power Station), therefore, should your customers decide to proceed with their connections onto your network there will be no requirement for an Appendix E to be added to your existing Bilateral Connection Agreements.

As this **Statement of Works** does not specify any works as being required nor any **Site Specific Requirements** as being necessary, our letter completes the process required for in respect of your **Request for a Statement of Works** for the purposes of CUSC Paragraph 6.5.1(a)(i).

All communication in relation to this **Statement of Works** should, in the first instance, be directed for the attention of Steph Wootton, who can be contacted by telephone on 01926 656126 or by email at steph.l.wootton@nationalgrid.com.

Yours faithfully



 **Vicky Higgin**
HEAD OF CUSTOMER SERVICE

FOR AND ON BEHALF OF
NATIONAL GRID ELECTRICITY TRANSMISSION PLC