

Mr Adam Pritchard
Primary System Design Engineer
Western Power Distribution (West Midlands) plc
Toll End Road
Tipton
DY4 0HH

Nicola Paton
Head of Customer Service

Nicola.Paton@nationalgrid.com

Direct tel +44 (0)1926 656703

Direct fax +44 (0)1926 656605

www.nationalgrid.com

30 June 2015

For the attention of Mr Adam Pritchard

Dear Sir

**Re: Request for Statement of Works received on 5 May 2015
For Embedded Generation of 217MW at Feckenham 400/66kV Substation
User Agreement Reference No. A/EM/90/7-7EX(3)**

I refer to your **Request for a Statement of Works** in relation to the possible connection of the above embedded generators to your **Distribution System** (the "Project"). **The Company** started processing this request on 3 June 2015.

We have now undertaken an initial assessment of the significance of the Project and believe the **Embedded Generators** does not have a significant impact on the **National Electricity Transmission System** (for the avoidance of doubt, such significant impact involves either party in an expenditure of more than £10,000) and would advise you of the following implications:-

- i. Requirement for works on the **National Electricity Transmission System** where such works are not at a **Connection Site**
NO
- ii. Requirement for works to the **National Electricity Transmission System** at a **Connection Site (Grid Supply Point)**
NO
- iii. Necessity for **Site Specific Requirements** (at the site of connection) of the **Embedded Generators**
YES

Western Power Distribution (WPD) shall ensure that each embedded small power station included in this submission shall have a reactive capability of between 0.95 Power Factor Lead to 0.95 Power Factor Lag allowing WPD to contain local voltage within acceptable limits at the Transmission Owner/Distribution Network Operator interfaces.

In addition, in accordance with the requirements of BC2.9.1.4, WPD shall maintain a facility such that under emergency conditions on the National Electricity Transmission System, WPD shall have the ability to de-energise the embedded generation upon instruction from The Company.

This **Statement of Works** is made on the basis of and is only valid in respect of the information provided by the **User** in the **Request for a Statement of Works**. If the **User** wishes to make any changes to any information submitted with the **Request for a Statement of Works** a new **Request for Statement of Works** must be submitted to **The Company** before **Energisation** of the connection can take place. Please note, you may not energise the connection of the Project without having received a written notification from **The Company** that the process set out in Paragraph 6.5 of CUSC has been complied with in full.

Please note this **Statement of Works** should be forwarded to the **Power Station** as soon as reasonably practicable in accordance with Paragraph 6.5.5.3 of the CUSC.

All communication in relation to this **Statement of Works** should, in the first instance, be directed for the attention of Steph Wootton, who can be contacted by telephone on 01926 656126 or by email at steph.l.wootton@nationalgrid.com

Yours faithfully



✍

NICOLA PATON
HEAD OF CUSTOMER SERVICE

FOR AND ON BEHALF OF
NATIONAL GRID ELECTRICITY TRANSMISSION PLC