

## WPD East Midlands Appendix G

| GSP                   | Part 1 [MW] | Part 2 [MW] | Part 3 [MW] | Part 4 [MW] | Part 5 [MW] | Capacity in Project Progression/ Modification Application [MW] | Total Aggregated Developer Capacity [MW] | Fault Level Headroom [kA] | Appendix G Approval Date |
|-----------------------|-------------|-------------|-------------|-------------|-------------|--|--|---------------------------|--------------------------|
| <b>Berkswell*</b>     | 25.3        | 63.9        | 0.0         | 0.0         | 0.0*        | 40   | 121.5                                    | 3.0                       | 23/07/2020               |
| <b>Bicker Fen</b>     | 346.1       | 139.1       | 0.0         | 0.0         | 25.9        | N/A  | 511.1                                    | 3.1                       | 23/07/2020               |
| <b>Chesterfield*</b>  | 259.1       | 415.7       | 0.0         | 6.00        | 0.0*        | 62.6   | 686.3                                    | 0.0*                      | 16/03/2020               |
| <b>Coventry</b>       | 153.4       | 277.2       | 0.0         | 0.0         | 23.2        | N/A  | 453.8                                    | 1.5                       | 23/07/2020               |
| <b>Drakelow</b>       | 45.0        | 102.4       | 0.0         | 40.0        | 74.5        | N/A  | 261.8                                    | 3.7                       | 23/07/2020               |
| <b>East Claydon*</b>  | 187.2       | 311.5       | 0.0         | 0.0         | 0.0*        | 43.7   | 505.0                                    | 0.0*                      | 23/07/2020               |
| <b>Enderby</b>        | 70.0        | 171.9       | 0.0         | 0.0         | 136.7       | N/A  | 378.7                                    | 4.1                       | 23/07/2020               |
| <b>Grendon*</b>       | 663.0       | 376.7       | 0.0         | 0.0         | 0.0*        | 247.4  | 1,069.8                                  | 2.6                       | 21/10/2019               |
| <b>Lea Marston</b>    | 21.7        | 161.7       | 0.0         | 0.0         | 0.9         | N/A  | 184.3                                    | 2.6                       | 23/07/2020               |
| <b>Ratcliffe</b>      | 196.9       | 186.2       | 0.0         | 0.0         | 31.6        | N/A  | 414.7                                    | 2.9                       | 23/07/2020               |
| <b>Staythorpe*</b>    | 298.0       | 447.5       | 0.0         | 0.0         | 0.0*        | 21.8   | 763.7                                    | 2.4                       | 23/07/2020               |
| <b>Stoke Bardolph</b> | 18.5        | 26.6        | 0.0         | 0.0         | 130.0       | N/A  | 175.1                                    | 3.4                       | 23/07/2020               |
| <b>Walpole</b>        | 198.4       | 134.1       | 0.0         | 0.0         | 60.0        | N/A  | 392.5                                    | 3.4                       | 23/07/2020               |
| <b>West Burton*</b>   | 30.3        | 161.5       | 230.9       | 0.0         | 0.0*        | 35.0   | 428.9                                    | 4.3                       | 04/05/2020               |
| <b>Willington</b>     | 386.6       | 113.7       | 0.0         | 0.0         | 62.2        | N/A  | 562.5                                    | 0.8                       | 23/07/2020               |

\*Connections at this GSP are subject to Project Progression or Modification Application submission as the volume of Accepted Generation has exceeded Materiality Headroom and/or Fault Level Headroom. Please note Materiality Headroom and/or Fault Level Headroom figures at this GSP are subject to Project Progression or Modification Application outcome. Please follow [this link](#) to view submission timescales.

| <b>Category of Connection</b>              |  |
|--|--|
| <b>Part 1</b>                              | Historic connections (No additions to this section)  |
| <b>Part 2</b>                              | Connections subject to technical conditions  |
| <b>Part 3</b>                              | Subject to interim restrictions on availability and subject to technical conditions  |
| <b>Part 4</b>                              | Generation that can only connect on completion of works to transmission system and subject to technical conditions   |
| <b>Part 5</b>                              | This figure will reduce as Developer Capacity is allocated or increase if projects cancel or disconnect. However, There is no guarantee or assurance that the capacity included in Part 5 will be available or that plant will be able to connect using it |
| <b>Total Aggregated Developer Capacity</b> | This figure cannot be changed or exceeded without submission of either a Modification Application, Project Progression or Statement of Works   |
| <b>Fault Level Headroom</b>                | The site fault level limit   |