

WPD East Midlands Appendix G

GSP	Part 1 [MW]	Part 2 [MW]	Part 3 [MW]	Part 4 [MW]	Part 5 [MW]	Capacity in Project Progression/ Modification Application [MW]	Total Aggregated Developer Capacity [MW]	Fault Level Headroom [kA]	Appendix G Approval Date
Berkswell*	25.3	249.4	0.0	0.0	0.0*	201.1	299.7	2.9	23/11/2021
Bicker Fen*	346.1	250.5	0.0	0.0	0.0*	25.0	620.2	2.8	23/11/2021
Chesterfield*	259.1	673.6	0.0	26.80	0.0*	126.7	977.5	2.1	23/11/2021
Coventry*	153.4	370.4	0.0	0.0	0.0*	90.1	557.7	0.0*	23/11/2021
Drakelow*	45.0	98.4	0.0	89.9	0.0*	107.0	261.8	3.6	22/07/2021
East Claydon*	187.2	221.6	0.0	226.8	0.0*	64.2	685.7	0.0*	18/11/2021
Enderby*	70.0	271.9	0.0	0.0	0.0*	154.9	378.7	3.4	23/11/2021
Grendon*	663.0	479.6	0.0	99.8	0.0*	196.9	1,249.3	0.0*	23/11/2021
Lea Marston	21.7	198.6	0.0	8.0	15.0	N/A	243.3	2.3	23/11/2021
Ratcliffe*	196.9	153.3	0.0	142.8	0.0*	382.5	510.0	0.0*	23/11/2021
Staythorpe*	298.0	621.1	0.0	0.0	0.0*	34.5	927.3	2.8	23/11/2021
Stoke Bardolph	18.5	30.6	0.0	0.0	126.0	N/A	175.1	3.3	23/11/2021
Walpole*	198.4	191.5	0.0	0.0	0.0*	169.8	392.5	3.1	23/11/2021
West Burton	30.3	161.5	94.0	40.0	50.0	N/A	376.7	3.0	17/05/2021
Willington	386.6	125.4	0.0	0.0	50.5	N/A	562.5	0.8	23/11/2021

*Connections at this GSP are subject to Project Progression or Modification Application submission as the volume of Accepted Generation has exceeded Materiality Headroom and/or Fault Level Headroom. Please note Materiality Headroom and/or Fault Level Headroom figures at this GSP are subject to Project Progression or Modification Application outcome. Please follow [this link](#) to view submission timescales.

Category of Connection	
Part 1	Historic connections (No additions to this section)
Part 2	Connections subject to technical conditions
Part 3	Subject to interim restrictions on availability and subject to technical conditions
Part 4	Generation that can only connect on completion of works to transmission system and subject to technical conditions
Part 5	This figure will reduce as Developer Capacity is allocated or increase if projects cancel or disconnect. However, There is no guarantee or assurance that the capacity included in Part 5 will be available or that plant will be able to connect using it
Total Aggregated Developer Capacity	This figure cannot be changed or exceeded without submission of either a Modification Application, Project Progression or Statement of Works
Fault Level Headroom	The site fault level limit