## **Connection Site:**

## Port Ham 132kV Substation

## Part 5 - Materiality & Wider System Limits

The following table sets out the indicative additional Developer Capacity as Materiality Headroom that the User can use as guidance for managing any future Relevant Embedded Power Station applications.

| Capacity Limit Summary  |                             |  |  |
|---|-----------------------------|--|--|
| Category of Connection  | MW                          |  |  |
| Part 1  | see summary<br>table        | Historic connections (No additions to this section)  |  |
| Part 2  | see summary<br>table        | Connections subject to technical conditions  |  |
| Part 3  | see summary<br>table        | Subject to interim restrictions on availability and subject to technical conditions  |  |
| Part 4  | see summary<br>table        | Generation that can only connect on completion<br>of works to transmission system and subject to<br>technical conditions   |  |
| Part 5 <b>Materiality Headroom</b><br>(non thermal)   | see summary<br>table        | This figure will reduce as Developer Capacity is<br>allocated or increase if projects cancel or<br>disconnect. However, There is no guarantee or<br>assurance that the capacity included in Part 5<br>will be available or that plant will be able to<br>connect using it. |  |
| (thermal)   | see summary<br>table        |  |  |
| Total Aggregated Developer<br>Capacity at the site must not<br>exceed this figure.  | <u>see summary</u><br>table | This figure cannot be changed or exceeded<br>without submission of either a Modification<br>Application, Project Progression or<br>Statement of Works  |  |
| Technical Condition Summary   |                             |  |  |
| Connection Asset Reverse<br>Power Limits<br>(Usually the SGT at the site, where<br>that SGT is classified as<br>connection) | 480 MVA                     | Where facilities exist, such as an ANM scheme,<br>to curtail generation in the event of a SGT circuit<br>fault this limit can be raised.   |  |
| Fault Level headroom  | see summary<br>table        | CB 380 1ph RMS break capability limits   |  |
| Voltage   | See Note                    | Voltages conditions apply to new generation projects.  |  |

June 2018

| Generator Technology  | See Note | The materiality headroom allocated at this GSP<br>will allow the connection of PV or wind<br>generation. No additional thermal generation or<br>storage can connect above what is listed in this<br>Appendix. |  |  |
|---|----------|---|--|--|
| <b>Comments/Constraints or Additional Restrictions</b> :<br>The materiality headroom allocated at this GSP will allow the connection of PV or wind generation<br>without constraint. Thermal plant can only connect on completion of works. |          |   |  |  |
| Transferable Capacity (see note below)  | 0 MW     | <b>GSP's:</b> N/A – MITS capacity not limiting this GSP.  |  |  |

June 2018