

WPD South West Appendix G

GSP	Part 1 [MW]	Part 2 [MW]	Part 3 [MW]	Part 4 [MW]	Part 5 [MW]	Capacity in Project Progression/Modification Application [MW]	Total Aggregated Developer Capacity [MW]	Fault Level Headroom [kA]	Appendix G Approval Date
Iron Acton*	85.8	176.3	0.0	0.0	0.0*	38.63	283.1	1.1	29/07/2020
Melksham	2.0	0.0	0.0	0.0	51.3	N/A	53.3	0.5	29/07/2020
Seabank	89.1	253.1	0.0	0.0	93.7	N/A	435.9	1.5	29/07/2020

*Connections at this GSP are subject to Project Progression or Modification Application submission as the volume of Accepted Generation has exceeded Materiality Headroom and/or Fault Level Headroom. Please note Materiality Headroom and/or Fault Level Headroom figures at this GSP are subject to Project Progression or Modification Application outcome. Please follow [this link](#) to view submission timescales.

Category of Connection	
Part 1	Historic connections (No additions to this section)
Part 2	Connections subject to technical conditions
Part 3	Subject to interim restrictions on availability and subject to technical conditions
Part 4	Generation that can only connect on completion of works to transmission system and subject to technical conditions

Part 5	This figure will reduce as Developer Capacity is allocated or increase if projects cancel or disconnect. However, There is no guarantee or assurance that the capacity included in Part 5 will be available or that plant will be able to connect using it
Total Aggregated Developer Capacity	This figure cannot be changed or exceeded without submission of either a Modification Application, Project Progression or Statement of Works
Fault Level Headroom	The site fault level limit