

SCHEDULE 1 - SPECIFIC TERMS FOR CONNECTION

Characteristics of the Supply of Electricity

Maximum Import Capacity:	xxx kVA
Maximum Export Capacity:	0 kVA
Voltage:	230/400 Volts
Phase:	Three Phase
Frequency:	50 Hertz
Current:	Alternating

General

The Maximum Import Capacity stated in this Schedule 1 has been requested by the Customer and agreed by the Company. The Maximum Import Capacity will be fixed for 12 months from the date that this Agreement takes effect unless increased by agreement between the Customer and the Company, in which case the increased Maximum Import Capacity will be fixed for a further 12 months from the date of increase.

Enduring Terms

The Customer agrees that the Company shall, on the application of any person purporting to be an owner and/or occupier (or prospective owner and/or occupier) of the Premises, be entitled to disclose to such person the fact that this Connection Agreement contains terms which differ from the terms set out in the National Terms of Connection (www.connectionterms.org.uk).

The Customer shall, prior to selling or leasing its interest in the Premises (or otherwise permitting a third party to occupy the Premises), ensure that the existence and provisions of this Connection Agreement are brought to the attention of such third party. For information, any such third party should note that it may automatically be bound by the provisions of this Connection Agreement in accordance with the National Terms of Connection (www.connectionterms.org.uk).

SCHEDULE 2 - CONNECTION POINTS & ASSET USE

Connection Point:

The outgoing terminals of the Company's fused cut-out or metering circuit breaker, as appropriate.

CONNECTION EXTENSION ASSETS

Relevant Connection Equipment:

LV underground cable extension and service termination equipment.

SHARED USE REINFORCEMENT ASSETS

Relevant Connection Equipment:

None.

SCHEDULE 4 - SITE RESPONSIBILITY SCHEDULES

Not used

SCHEDULE 5 - SITE SPECIFIC OPERATING ARRANGEMENTS

Not used

SCHEDULE 6 - SITE SPECIFIC TECHNICAL CONDITIONS

The short-term flicker severity, Pst, as defined in Engineering Recommendation P28, caused by the Customer's Installation shall be limited to 0.5 at the point of common coupling.

The Customer's Installation shall be designed such that it is possible, if so required, to introduce sequential switching to ensure a minimum period between each operation that causes voltage change consistent with the above flicker limit; examples include switching of each generator, switching of each transformer, switching of load etc. The magnitude of the voltage change caused by the operation of the Customer's Installation shall be limited to 3% for events no more frequent than once every 10 minutes; for infrequent events, no more frequent than once per three months, this value is increased to 6%; for very infrequent events, no more frequent than once per year, this value is increased to 10%.

SCHEDULE 7 - ACCOMMODATION

Where it is necessary to establish a Substation on the Customer's Premises the Customer must provide accommodation for the Company's Equipment on the Customer's Premises which will allow an electricity supplier to supply the Customer and other customers with electricity.

Where accommodation is required pursuant to the above, the Customer must:

- (a) comply with any of the specific terms set out in this Schedule with regard to that accommodation;
- (b) unless the Company already have a lease of the Substation accommodation or the Customer have agreed to sell the Company the freehold or the Company deem it unnecessary, the Customer will grant or arrange for the grant of a lease of the Substation accommodation to the Company at a nominal price within twenty eight days of the date of the Company's written request. Each party shall bear its own costs in relation to the transaction; and
- (c) that the Customer will keep all parts of the Substation accommodation in good order, repair and condition including the interior surface and/or cladding and/or boundary fences which enclose or form part of the Substation accommodation.

Where the Company are to take a lease of the Substation accommodation, the form of the lease shall be substantially as set out in the Appendix to this Agreement. The Company will be responsible for the reasonable costs of preparing and producing the lease. If the Customer is a leasehold owner, the length of the Customer's lease to the Company will be for 99 years or for the length of the Customer's leasehold ownership if that is less than 99 years.