

**Connection Site:** Aberthaw 132kV Substation

**Part 5 - Materiality & Wider System Limits**

The following table sets out the indicative additional Developer Capacity as Materiality Headroom that the User can use as guidance for managing any future Relevant Embedded Power Station applications.

<b>Capacity Limit Summary</b>		
<b>Category of Connection</b>	<b>MW</b>	
Part 1	<a href="#"><u>see summary table</u></a>	Historic connections (No additions to this section)
Part 2	<a href="#"><u>see summary table</u></a>	Connections subject to technical conditions
Part 3	<a href="#"><u>see summary table</u></a>	Subject to interim restrictions on availability and subject to technical conditions
Part 4	<a href="#"><u>see summary table</u></a>	Generation that can only connect on completion of works to transmission system and subject to technical conditions
<b>Part 5 Materiality Headroom</b>	<a href="#"><u>see summary table</u></a>	This figure will reduce as Developer Capacity is allocated or increase if projects cancel or disconnect. However, There is no guarantee or assurance that the capacity included in Part 5 will be available or that plant will be able to connect using it.
<b>Total Aggregated Developer Capacity at the site must not exceed this figure.</b>	<a href="#"><u>see summary table</u></a>	<b>This figure cannot be changed or exceeded without submission of either a Modification Application, Project Progression or Statement of Works</b>
<b>Technical Condition Summary</b>		
<b>Connection Asset Reverse Power Limits</b>  (Usually the SGT at the site, where that SGT is classified as connection)	N/A	Where facilities exist, such as an ANM scheme, to curtail generation in the event of a SGT circuit fault this limit can be raised.
<b>Fault Level headroom</b>	<a href="#"><u>see summary table</u></a>	CB M70/M90 RMS break capability limits
<b>Voltage</b>	See Note	Voltages conditions apply to new generation projects.

<b>Generator Technology</b>	See Note	The materiality headroom allocated at this GSP will allow the connection of PV or wind generation. No additional thermal generation or storage can connect above what is listed in this Appendix.
<p><b>Comments/Constraints or Additional Restrictions:</b></p> <p>The materiality headroom allocated at this GSP will allow the connection of PV or wind generation without constraint. Further thermal generation and/or storage will not be able to connect above those levels in this Appendix and a Modification Application must be submitted to assess the works required to connect this additional capacity</p>		
<b>Transferable Capacity (see note below)</b>	<b>50 MW</b>	<b>GSP's: Cardiff East and Uskmouth 20MW transferred from Cardiff East</b>

