

## EXPORT LIMITATION SCHEME APPLICATION FORM

This form should be used by all applicants considering installing an **ELS** as part of their connection application. This form should accompany the application for a connection.

<b>Customer Name</b>	<b>Project Name :</b>
<b>Application Submission Date:</b> __ / __ / ____	<b>WPD CROWN Ref No</b>

The following information shall be submitted with the enquiry:

<b>Copy of Single Line Diagram of Export Limitation Scheme</b>
<p>Explanation / description of <b>Export Limitation Scheme</b> operation including a description of the fail-safe functionality e.g. the response of the scheme following failure of a:</p> <ul style="list-style-type: none"> <li>• <b>Power Monitoring Unit</b></li> <li>• <b>Control Unit</b></li> <li>• <b>Generator Interface Unit</b></li> <li>• <b>Demand Control Unit</b></li> <li>• <b>Communication Equipment</b></li> </ul> <p><i>Note, fail-safe operation is not mandatory where the installation has an aggregate <b>Generating Unit</b> capacity of 16A (i.e. 3.68kW) per phase or less.</i></p>
<p>Is additional reverse power protection to be provided (mandatory for connection voltages above 1,000V)</p> <p>Yes / No*</p> <p>* (delete as necessary)</p>
Required Import Capacity (kW):
Proposed Export Capacity (kW) if known:
<p>Total <b>Power Station Capacity</b>** (kW):</p> <p>** aggregate kW rating of all the electrical energy sources (<b>Generating Units</b> including storage)</p>