

WPD East Midlands Appendix G

GSP	Part 1 [MW]	Part 2 [MW]	Part 3 [MW]	Part 4 [MW]	Part 5 [MW]	Capacity in Project Progression/ Modification Application [MW]	Total Aggregated Developer Capacity [MW]	Fault Level Headroom [kA]	Appendix G Approval Date
Berkswell	25.3	84.9	0.0	0.0	11.3	N/A	121.5	2.7	21/10/2019
Bicker Fen	346.1	141.2	0.0	0.0	23.8	N/A	511.1	2.8	21/10/2019
Chesterfield*	259.1	328.7	0.0	49.9	0.0*	117.0	686.3	0.0*	21/10/2019
Coventry*	153.4	182.4	0.0	0.0	0.0*	23.3	362.4	3.7	21/10/2019
Drakelow	45.0	211.4	0.0	0.0	21.5	N/A	261.8	2.8	21/10/2019
East Claydon	187.2	238.9	0.0	0.0	78.8	0.0	505.0	0.7	21/10/2019
Enderby	70.0	181.2	0.0	0.0	127.4	0.0	378.7	4.1	21/10/2019
Grendon*	663.0	376.7	0.0	0.0	0.0*	138.8	1,069.8	2.6	21/10/2019
Lea Marston	21.7	113.3	0.0	0.0	49.9	N/A	183.3	2.8	21/10/2019
Ratcliffe	196.9	163.0	0.0	0.0	54.8	N/A	414.7	3.1	21/10/2019
Staythorpe	298.0	253.7	0.0	0.0	212.0	N/A	763.7	3.5	21/10/2019
Stoke Bardolph	18.5	26.6	0.0	0.0	130.0	N/A	175.1	3.4	21/10/2019
Walpole	198.4	147.1	0.0	0.0	47.0	0.0	392.5	3.1	21/10/2019
West Burton	30.3	199.5	190.9	0.0	8.2	N/A	428.9	4.1	21/10/2019
Willington	386.6	113.7	0.0	0.0	62.2	N/A	562.5	0.8	21/10/2019

*Connections at this GSP are subject to Project Progression or Modification Application submission as the volume of Accepted Generation has exceeded Materiality Headroom and/or Fault Level Headroom. Please note Materiality Headroom and/or Fault Level Headroom figures at this GSP are subject to Project Progression or Modification Application outcome. Please follow [this link](#) to view submission timescales.

Category of Connection	
Part 1	Historic connections (No additions to this section)
Part 2	Connections subject to technical conditions
Part 3	Subject to interim restrictions on availability and subject to technical conditions
Part 4	Generation that can only connect on completion of works to transmission system and subject to technical conditions
Part 5	This figure will reduce as Developer Capacity is allocated or increase if projects cancel or disconnect. However, There is no guarantee or assurance that the capacity included in Part 5 will be available or that plant will be able to connect using it
Total Aggregated Developer Capacity	This figure cannot be changed or exceeded without submission of either a Modification Application, Project Progression or Statement of Works
Fault Level Headroom	The site fault level limit