

WPD South West Appendix G

GSP	Part 1 [MW]	Part 2 [MW]	Part 3 [MW]	Part 4 [MW]	Part 5 [MW]	Capacity in Project Progression/Modification Application [MW]	Total Aggregated Developer Capacity [MW]	Fault Level Headroom [kA]	Appendix G Approval Date
Iron Acton	85.8	180.7	0.0	0.0	16.6	N/A	283.1	1.3	07/10/2019
Melksham	2.0	0.00	0.0	0.0	51.3	N/A	53.3	0.5	07/10/2019
Seabank	89.1	234.1	0.0	0.0	112.7	N/A	435.9	1.9	07/10/2019

Category of Connection	
Part 1	Historic connections (No additions to this section)
Part 2	Connections subject to technical conditions
Part 3	Subject to interim restrictions on availability and subject to technical conditions
Part 4	Generation that can only connect on completion of works to transmission system and subject to technical conditions
Part 5	This figure will reduce as Developer Capacity is allocated or increase if projects cancel or disconnect. However, There is no guarantee or assurance that the capacity included in Part 5 will be available or that plant will be able to connect using it
Total Aggregated Developer Capacity	This figure cannot be changed or exceeded without submission of either a Modification Application, Project Progression or Statement of Works
Fault Level Headroom	The site fault level limit